

This Addendum is issued for purposes of clarification and/or revision of the contract documents.
There are **03** pages in this addendum, including all attachments.

SPECIFICATIONS

A. N/A

SHEETS – ELECTRICAL

A. SHEET E0.01 – ELECTRICAL LEGEND AND ABBREVIATIONS:

1. ADD GENERAL NOTES 3 & 4:

- 3. CORE DRILL WHERE REQUIRED FOR SLEEVES AND PENETRATIONS.
- 4. MAINTAIN EXISTING FIRE WALL RATINGS. FIRE SEAL AROUND SLEEVES AND INSIDE SLEEVES WHERE REQUIRED BY CODE.

THERE ARE 03 PAGES IN THIS ADDENDUM, INCLUDING ALL ATTACHMENTS.

BIDDERS SHALL NOTIFY ALL SUB-BIDDERS INVOLVED AND SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE COMPLETED AND SUBMITTED FORM OF BID.

THIS ADDENDUM MUST BE CLIPPED DIRECTLY TO YOUR COPY OF THE SPECIFICATIONS AND BOTH RETURNED AFTER BID DATE.

END OF ADDENDUM NO. 2

Attachments:

-2022-05-06 KILO Pre-Bid Walk Sign In sheet



Meeting Agenda

Notes By: Ryan Rood

The intent of this meeting: Pre-Bid Site Walk

Topics of discussion:

1. Overview of Project.
2. Overview of Contract / Bid Requirements.
3. Reminder of Bid timeline and dates:
 - a. Addendum 1 (released)
 - b. Addendum 2 5/10/22
 - c. Addendum 3 5/16/22
 - d. Bid 5/20/22
4. Submit Bid Questions to BCE. Answers or clarifications will be provided in addendums only.
 - a. TO: Carrie.Taylor@bceeengineers – CC Ryan.Rood@bceengineers.com