

## FWPS-022020 Questions

**RFP Update:** Request for Proposal was advertised in the Daily Journal of Commerce on Feb 26 & Mar 2, 2020 (Previously planned for Feb 24 & Mar 2).

**Question:** The Optional School Walk-thru for Fiber Cabling (Appendix C) states that it is on Wednesday, March 10th, 2020 at 8am at Todd Beamer High School.

**Answer:** The operational School walk-thru is scheduled for Tuesday, March 10<sup>th</sup> starting at Todd Beamer High School at 8 am.

**Question:** Appendix C Scope of Work states that the contractor is to install 12 port LC style connector plate in existing fiber trays as space allows. FWPS to provide additional 1U rack mount fiber tray if needed.

Please confirm that the contractor is to provide the 12 port LC style connector plate or are the plates provided by FWPS akin to the 1U rack mount fiber tray?

If the contractor is to provide the connector plate, please provide the manufacturer of the existing rack mount fiber trays.

**Answer:** Project bid is to include 12 port LC style connector plates for any sites as needed. Specific fiber tray needs will be identified during walk-thru. If additional fiber trays are needed, FWPS will provide 1U Leviton Opt-X 5R1UM-\*03 fiber tray.

TC 3-5-20